



**qathet
REGIONAL DISTRICT**

ADDENDUM #1

Request for Tender

Myrtle Pond Water System Well Drilling

Issue Date: January 29, 2026

Addendum Contents: These 2 pages

This addendum shall form part of the Request for Proposal document and is to be read and coordinated with all other parts.

Question 1: Given the nature of well development, it is unknown how long the well will take to develop. How many hours of development time should we include in our tender price?

Answer 1: Allow 24 hours of development time, and provide an hourly rate for time exceeding 24 hours.