

DRINKING WATER SYSTEM ANNUAL REPORT

Reporting Period: January 1st to December 31st, 2025 (year)

Water System Northside Firehall #2

Water System Owner qathet Regional District

Primary Contact Name (operator or Manager) Regan Keil, Parks and Properties Supervisor

Phone Number (Operator or Manager) 604-485-2260 ext 408

E-mail (Operator or Manager) rkeil@qathet.ca

DESCRIBE YOUR WATER SUPPLY SYSTEM

What is the Source(s) of Raw Water?

Deep Well Shallow Well Surface Water Other

If other, specify details:

Does the Drinking Water System have Primary Disinfection?

Yes No

Chlorination Ultraviolet Light Ozone Other

If other, specify details:

Does the Drinking Water System have Secondary Disinfection?

Yes No

Chlorination Other

If other, specify details:

Does the Drinking Water System have Filtration?

Yes No

Check all boxes that apply

Cartridge Filter(s) Carbon Filter Sand Filtration Reverse Osmosis Other

If other, specify details:

PUBLIC REPORTING

Emergency Response & Contingency Plan (ERCP)

Is your ERCP up to Date? Yes No

How do you Inform the System Users of the ERCP?

Hand Delivered Bulletin Board Newspaper Utility Bill Insert Website
 Other (specify details)

Drinking Water System Annual Report**How do you Inform the System Users of the Annual Report?**

Hand Delivered Bulletin Board Newspaper Utility Bill Insert Website
 Other (specify details)

COMPLIANCE WITH OPERATING PERMIT

List the conditions of your Operating Permit (Contact the DWO for a copy if needed):

Minimum bacteriological sampling frequency is monthly.

Review and update the Emergency Response Plan annually.

Wellhead protection plan to be submitted by Nov. 1, 2022.

Are you in compliance with your Operating Permit? Yes No

BACTERIOLOGICAL TESTING AND DRINKING WATER PROTECTION REGULATION WATER QUALITY STANDARDS

How many bacteriological samples were collected during this reporting period?

13

What is the minimum required sampling frequency for this system? (#samples/month)

1/month

Additional sampling details:

Was the minimum required sampling frequency achieved? Yes No

Comments:

Bacteriological summary attached to this report? Yes No***If no, how do the users of the system view the results?***

WATER QUALITY STANDARDS FOR POTABLE WATER

Parameter:	Standard:	Did this system meet standard?	
Escherichia coli (for all samples)	No detectable <i>Escherichia coli</i> per 100ml	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Total Coliform Bacteria (if only 1 sample collected in a 30 day period)	No detectable total coliform bacteria per 100ml	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Total Coliform Bacteria (if more than 1 sample collected in a 30 day period)	No more than 10% of samples contain total coliform bacteria, and No sample has more than 10 total coliform bacteria per 100ml	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No

If the system did not meet any of above Drinking Water Protection Regulation standards, record the results in the table below; attach additional sheets if necessary.

Date	TC/100ml	E.coli/100ml	Reason	Corrective Action

CHEMICAL SAMPLING COMPLETED DURING THIS REPORTING PERIOD

<i>Was any chemical sampling conducted during reporting period?</i>		<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
<i>If no, when were the last chemical samples conducted for this system?</i>		<i>If yes, did all water samples meet the Guidelines for Canadian Drinking Water Quality?</i>	
(date) 07/14/2021	<input type="checkbox"/> Don't Know	<input type="checkbox"/> Never	<input checked="" type="checkbox"/> Yes

If any water samples did not meet the Guidelines for Canadian Drinking Water Quality, record the results in the table below; attach additional sheets if necessary.

Parameter	Result	Corrective Action / Treatment / Comments

ADDITIONAL TESTING

Does the system have analyzers for continuous monitoring? Yes No

If yes, check all boxes that apply:

Chlorine Turbidity Other (details)

Are the results available on request?

If any additional testing or sampling was conducted, record results in the table below; attach additional sheets if necessary.

Additional Testing & Reason for Sampling	Corrective Action Taken

WATER QUALITY COMPLAINTS

Were there any water quality complaints in this reporting period? (e.g. taste, odour, colour etc.) Yes No

If yes, complete the table below; attach additional sheets if necessary.

Date	Water Quality Complaint	Corrective Action / Treatment

OPERATIONAL PROBLEMS

Were there any operational problems during this reporting period? (e.g. insufficient water supply, malfunction of disinfection equipment, line breaks, elevated turbidity etc.).

 Yes No

If yes, complete the table below; attach additional sheets if necessary.

Incident Date	Type of Operational Problem	Corrective Action Taken

MAJOR UPGRADES/REPAIRS & EXPENSES

Were there any major upgrades/repairs or any major costs incurred during this reporting period?

 Yes No

If yes, complete the table below; attach additional sheets if necessary.

Major Upgrades/Expenses	Details
Improvements required by DWO	
Additions/changes to system	
Purchase or install new equipment	
Equipment repair or replacement	
Annual maintenance of system	
Specialist report	
Other	

FUTURE IMPROVEMENTS

Are there any plans for future improvements?

 Yes No

If yes, complete the table below; attach additional sheets if necessary.

Future Upgrades or Improvements	Estimated Date of Completion

Click here to enter a date.

DATE COMPLETED: 2026 01 12

COMPLETED BY: Regan Keil

NVFD 2 (Roots Way) - POWELL RIVER COMMUNITY HEAI

YEAR	DATE	INSIDE TAP			OUTSIDE TAP		
		TC*	EC**	CMT	TC*	EC**	CMT
					LT1	LT1	
2025	14-Jan				LT1	LT1	
	19-Feb				LT1	LT1	
	18-Mar				LT1	LT1	
	15-Apr				Timed	Timed	
	27-May				LT1	LT1	
	23-Jun				LT1	LT1	
	15-Jul				LT1	LT1	
	19-Aug				LT1	LT1	
	17-Sep				LT1	LT1	
	7-Oct				LT1	LT1	
	3-Nov				LT1	LT1	
	1-Dec	LT1	LT1		LT1	LT1	

EST: EST result indicates high colony density on membrane preventing accurate coliform counting.

BWA: Boil Water Advisory

OG: Overgrown - confluent bacterial growth on membrane preventing accurate coliform determination

~ More than 200 background colonies noted on total coliform

membrane filter per 100 ml. Indicates system requires flushing

Indicates high colony density on membrane preventing accurate coliform counting

* Total Coliform per 100 mL

** E. Coli per 100 mL

CMT Comment

L Less than