



qathet
REGIONAL DISTRICT

ADDENDUM #2

Request for Tender: 1220-346

Palm Bear Regional Park Washroom Building Roof Replacement 2026

Issue Date: September 1, 2026

Addendum Contents: These 2 pages

This addendum shall form part of the Request for Tender document and is to be read and coordinated with all other parts.

Question 1: The Scope of work for the project states installing 3/8" plywood overtop of the wood strapped roof deck. However, 3/8" plywood does not meet the building requirement and should be 1/2" plywood. Installation overtop of 3/8" plywood does not meet the fastening pull strength requirements for the new metal roof and is not warrantable. Please advise on how to proceed.

Answer 1: Please bid using the 1/2" plywood.